

List of Acceptable Make for Electrical Materials (As on 01.12.2025)

1	M.S/Steel Conduct	NIC/AKG/BEC/Steel Craft
2	PVC Conduit Pipe	BEC/AKG/Finolex (ISI mark only)
3	PVC Insulated Wire	Havells/Finolex/KEI/ Polycab / Rallison
4	Telephone Wire & Cables	Delton/Havells/KEI/Finolex/Polycab/Rallison
5	PVC / XLPE Insulated PVC Sheathed Power Cable 1.1 KV / 11 KV	Polycab/Havells/ Finolex /KEI / Rallison
6	MCCB/ACB	Siemens/ABB/ Schneider/Lauritz Knudsen
7	Changeover Switch	HPL-Socomec/ Schneider/ Siemens/Lauritz Knudsen
8	MCB/Isolator/DBs	Legrand/ Schneider /ABB/ Lauritz Knudsen
9	Voltmeter/Ammeter	Lauritz Knudsen/Siemens/Legrand/ABB/ Schneider
10	Selector Switches	Lauritz Knudsen /Siemens/Legrand/ABB/ Schneider
11	Indicating Light	Lauritz Knudsen /Siemens/Legrand/ABB/ Schneider
12	Thimbles	Jonson/Dowells / Action
13		
14	G.I. Pipe	Jindal Hisar/Tata/Prakash/Surya
15	Power Contractor	Lauritz Knudsen /Siemens/ Schneider /ABB/Crompton
16	Motor Starter	Lauritz Knudsen /Siemens/ Schneider /ABB/Crompton
17	Feeder pillar/L.T. panel	Only C.P.R.I. approved fabricators having in house seven tank treatment facilities.
18	Piano type Switch / Socket	Anchor / Cona
19	Modular Switches / Socket and accessories	Legrand/M.K./North West/Crab Tree/Anchor Roma/Honeywell
20	U-PVC trunking & Accessories	Legrand/M.K./North West/Honeywell
21	LED Fixture and lamps:	Crompton/ Philips/ Wipro /Havells /Surya /Bajaj / Halonix/Orient
22	Ceiling Fan	USHA/Crompton/Havells/Khaitan/Orient / Polycab
23	Exhaust Fan	USHA/Crompton/Havells/Khaitan/Orient / Polycab
24	HDPE Pipe	ISI Marked

All the wires used shall be F.R.L.S. grade multi-strand type.

All the materials brought at site should be got prior approval of EE (E).



Assistant Engineer



Superintending Engineer