

Date: 9-02-2026

CORRIGENDUM

Tender for Upgradation of Precision Air Conditioning (PAC) & CIS Data Centre (DC) in JNU New Delhi

Tender No: JNU/CIS/2026/UPGRADATION OF PAC & DC/01
Dated: 21-01-2026

With reference to the above-mentioned tender published on the CPP, the following amendments/clarifications are hereby issued. Bidders are advised to take note of the following corrigendum details before submission of their bids:

(I) Amendments:

1. Page 21: Humidifier Section

It is hereby clarified that the humidifier technology may be Infrared / Electrode / Steam / Ultrasonic or equivalent/better technology.

The quoted humidifier must work on raw water supply and the bidder should provision the complete water treatment system without any cost extra to the university and without any impact on running of the system in 24x7 operation.

2. Page No 8: General Eligibility Criteria Section

S. No 8: The bidder shall have on its payroll at least (01) Certified Data Centre Professionals (CDCP) or one (01) Certified Data Centre Specialist (CDCS) to execute and support the work under this contract. Documentary proof to this effect shall be submitted along with the Technical Bid.

3. Page No 22: Microprocessor controller

The tender specifies a microprocessor-based controller with defined functional and monitoring requirements. The Touch-screen based controllers offering equivalent or higher functionality are acceptable without any extra cost to the university.

(II) Clarifications

1. Page No 18: BOQ (BILL OF QUANTITY)

S.No 1.1 and 1.2:

Unit Discharge type: Top Suction (return air entry) and Bottom Discharge (air pushed into raised floor) only.

2. Page 18 and Page 21:

Both Digital Scroll compressor and/or inverter scroll compressor are allowed.

3. Page No 30:

Bidders seeking exemption from submission of EMD must submit valid supporting documents for the relevant category, as per Government of India policy applicable to MSMEs (Micro and Small Enterprises), along with their bid. The EMD exemption will be dealt as per the Govt. of India Policy.

4. Monitoring (Page No. 22)

The unit shall be supplied with suitable provisions for both SNMP & Modbus connectivity without any extra cost to the university.

Bid Submission Closing Date & Time: 16th Feb 2025 4:00PM

Note: There is no change in any other terms and conditions of the tender document. However, all bidders are advised to regularly visit the CPP Portal and the official website of the University for any Further Updates or information until the last date for submission of bids as specified in the tender document. **The procurement is subject to the availability and allocation of funds by the competent authority under the relevant budget head.**